


ವೆಬ್‌ಸೈಟ್ : www.hospetcity.gov.in
mail ID : commissionerhpt@yahoo.com
staff ulb hospet@yahoo.com




ದೂರವಾಣಿ : 08394-224041
ಪ್ಯಾಕ್ಸ್ : 08394-224041



ನಗರಸಭಾ ಕಾರ್ಯಾಲಯ ಹೊಸಪೇಟೆ-583201

ನೀರು ಅಮೂಲ್ಯವಾದದ್ದು ಅದನ್ನು ಮಿತವಾಗಿ ಬಳಸಿ
“ ಪ್ರಾಥಮಿಕ ಬಳಕೆ ನಿಷೇಧಿಸಿ ಪರಿಸರ ರಕ್ಷಣೆಗೆ ಕೈ ಜೋಡಿ



SAFE DRINKING WATER AND SANITARY CONDDITION CERTIFICATE

No: CMC/SDWS/2024-25

Date: 18.03.2025

It is certified that an inspection team headed by **Virupaxappa N H**, SENIOR HEALTH INSPECTOR from CITY MUNICIPALITY COUNCIL, HOSPET. Inspected the **CHAITANYA TECHNO LOWER PRIMARY SCHOOL, BESIDE HAMPI INTERNATIONAL HOTEL RAILWAY STATION ROAD HOSAPETE** on 17.03.2025 and found that the **CHAITANYA TECHNO LOWER PRIMARY SCHOOL, BESIDE HAMPI INTERNATIONAL HOTEL RAILWAY STATION ROAD HOSAPETE** has Safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & campus as per the norms prescribed by the Central/State /U.T. Govt.

The above valid for a period of **ONE YEAR** (From the date of Issue)

Signature with seal


(Virupaxappa N H)

SENIOR HEALTH INSPECTOR
CMC HOSPET-583201.

To,
Principal/Secretary,
CHAITANYA TECHNO LOWER PRIMARY SCHOOL,
BESIDE HAMPI INTERNATIONAL HOTEL,
RAILWAY STATION ROAD HOSAPETE-583231
VIJAYANAGAAR(Dist)


PRINCIPAL

SRI CHAITANYA TECHNO LOWER PRIMARY SCHOOL
(Aff.No:830857 & SCHOOL CODE: 45762)
BESIDE HAMPI INTERNATIONAL HOTEL
RAILWAY STATION ROAD,
HOSAPETE-58320.
BALLARI DIST: KARNATAKA
Email:hospet@srichaitanyaschool.net
Mobile: 702264


Manager
Nexgen Educational Trust

RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
RDWS&D Sandur Sub Division Laboratory.

TEST REPORT					
SRI CHAITANYA TECHNO LOWER PRIMARY SCHOOL BEHIND RAILWAY STATION NEAR HAMPI HOTEL HOSAPATE. PIN: CODE 583201 BOREWELL				Report date: 17/02/2025 Report Number: RDWSSUN/-----/2025 Reference: Sample receipt Form Sample receipt date: _____ Sample code: ----- Date of Sample collection: -----/-----/2025 Analysis start date: : -----/-----/2025 Analysis completion date: : -----/-----/2025 Sample collection protocol: IS 3025(Part-1)	
Sample Particulars:				Sample quantity: 1 ltr	
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description:					
1.	pH Value @Temp°C	7.29	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 1983
2.	Specific Conductance, µS/cm@Temp°C	600	—	—	IS 3025 (Part-14) : 1984
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Colour, Hazen Units	Agreeable	Agreeable	15	IS 3025 (Part-4) :1983
5.	Turbidity, NTU	0.4	5	5	IS 3025 (Part-10) : 1984
6.	Total Dissolved Solids@ 105°C, mg/l	390	500	2000	IS 3025 (Part-16) : 1984
7.	Alkalinity as CaCO ₃ , mg/l	141.84	200	600	IS 3025 (Part-23) : 1986
8.	Total Hardness as CaCO ₃ , mg/l	164.78	200	600	IS 3025 (Part-21) : 2009
9.	Calcium as Ca, mg/l	40.83	75	200	IS 3025 (Part-40) : 1991
10.	Magnesium as Mg, mg/l	15.24	30	100	IS 3025 (Part-46) : 1994
11.	Chloride as Cl, mg/l	75.76	250	1000	IS 3025 (Part-32) : 1988
12.	Sulphate as SO ₄ , mg/l	69.76	200	400	IS 3025 (Part-24) : 1986
13.	Fluoride as F, mg/l	0.615	1	1.5	APHA 23 rd Edition
14.	Nitrate as NO ₃ , mg/l	21.05	45	No relaxation	APHA 23 rd Edition
15.	Iron as Fe, mg/l	0.0018	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above tested water sample meet the requirement of IS 10500:2012 RA 2018 drinking water specification. Drinking water specification hence the source of sample shall be used for drinking purpose.					
<div style="display: flex; justify-content: space-between; align-items: center;"> <div style="text-align: left;"> ANALYST </div> <div style="text-align: center;"> </div> <div style="text-align: right;"> </div> </div> <div style="display: flex; justify-content: space-between; align-items: center; margin-top: 10px;"> <div> SRICHAITANYA TECHNO LOWER PRIMARY SCHOOL (PIN No: 583201 & SCHOOL CODE: 45262) BESIDE HAMPI INTERNATIONAL HOTEL RAILWAY STATION ROAD, HOSAPATE BALLARI D </div> <div style="text-align: right;"> Manager Nexgen Educational Trust </div> </div> <div style="display: flex; justify-content: center; align-items: center; margin-top: 10px;"> <div> Email: hospet@srichaitanyaschool.net Mobile: 7022640824 </div> </div>					

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.